

ADDENDUM NO.3
TO
PLANS AND SPECIFICATIONS
FOR
EDITH KANAKA'OLE MULTI-PURPOSE STADIUM
BUILDING ADDITION & IMPROVEMENTS
JOB NO. PR-4166
SOUTH HILO, HAWAI'I
COUNTY AND STATE OF HAWAI'I

NOTICE TO BIDDERS

The items listed below are made a part of the current contract and shall govern the work, taking precedence over the previously issued specifications and drawings governing the particular item of work mentioned.

SPECIFICATIONS

ITEM NO. 1 – Specification Section 01040

ADD “d.” to Part **1.05 C**. Temporary Requirements to be provided:

- d. The Contractor shall furnish and install and or accommodate any item or utility taken out of service during construction such as power and potable water. The Contractor shall be responsible for coordination, and bear all costs associated with relocation, fees, and temporary services and all appurtenances.

REQUEST FOR INFORMATION/REQUEST FOR CLARIFICATION

1. **QUESTION:** *The Termite Control Barrier System (stainless steel mesh) is a stand-alone termite barrier IF a full installation is done. However, if the specifications is calling out for a partial termimesh installation, i.e., all pipe penetrations through the building slab, (and not other voids where termites come through in a building for example- cold joints, construction joints), then the stainless steel termite barrier is partial installation and must be installed in conjunction with another termite control per the building code. The Dept of Education sometimes approaches termite control in an integrated manner where they specify either/or BTB/Soil treatment with stainless steel termite*

barrier on all pens. In the specifications for the Edith Kanaka'ole Multi-Purpose Stadium project the either/or option of the three stated termite control methods is not an option for stainless steel termite barrier if the intent is for a partial stainless steel termite control barrier installation for pens only.

RESPONSE: Any potential entry point, including vertical joints and penetrations, through the building slab must be protected.



Warren H. W. Lee, P.E., Director
Department of Public Works
County of Hawai'i

Date Issued: November 27, 2012

Please detach and execute the receipt below. Return immediately via facsimile (808) 961-8630 or mail to the Administration Office, Department of Public Works, County of Hawai'i at Aupuni Center, 101 Pauahi Street, Suite 7, Hilo, HI 96720-4224.

Receipt of Addendum No. 3 via website for the EDITH KANAKA'OLE MULTI-PURPOSE STADIUM BUILDING ADDITION & IMPROVEMENTS, Job No. PR-4166, South Hilo, Hawai'i, is hereby acknowledged.

Signed _____ Title _____

Firm _____ Date _____